

**Response of  
Wisconsin Power and Light Company  
to  
The Public Service Commission of Wisconsin  
Data Request No. 3.14**

Docket Number: 05-CE-137  
Date of Request: March 11, 2009  
Information Requested By: Ken Detmer  
Date Responded: March 30, 2009  
Author: Joe Holliman  
Author's Title: Sr Asset Strategy Consultant  
Author's Telephone No.: (608) 458-3841  
Witness: (If other than Author)

---

**Data Request No. 3.14:**

Follow-up to Question 1.22: Does EGEAS modeling provided assume Edgewater 3 is retired?

**Response:**

The EGEAS modeling presented in Table 5 and Appendix D of the initial application presumed the approval of the Nelson Dewey 3 project and the retirement of Edgewater Unit 3 at the end of 2012, which was a part of the carbon reduction plan that WPL proposed to implement contingent upon approval of Nelson Dewey 3.

The updated EGEAS assumes that Edgewater Unit 3 is retired at the end of 2023. This assumption is for modeling purposes only and does not reflect a determination by WPL regarding the actual retirement date for Edgewater Unit 3.